

Instructions for Well Disinfection

Your water sample showed bacteriological contamination. **DO NOT DRINK THIS WATER. IT MUST BE BOILED FOR 10 MINUTES BEFORE USING FOR DRINKING OR IN FOOD PREPERATION.**

Follow the directions below for disinfecting the well and pipes. Recollect your sample into a sterile bottle provided by Avocet and return to the lab within 24 hours of collection.

Avocet's Sample Drop-Off Hours: Monday: Thursday 8am-5pm
Friday: 8am-4pm

Disinfection Procedure:

1. Use one gallon of fresh household bleach.
2. Mix the bleach in 5 to 10 gallons of clear water. Pour half of it directly into the well. If possible, pour the remainder in so that the sides of the casing are washed down.
3. After the bleach is added, turn on the taps in the house until the odor or taste of chlorine can be detected, then turn off taps. Do the same for all other taps and faucets in the house. If you have a treatment system on your water, you may need to by-pass the treatment unit so that it is not damaged by the bleach.
4. Allow the bleach to remain in the well and pipes at least overnight, 24 hours if possible. Turn on the outside taps until the smell of chlorine can no longer be detected; then do the same with taps inside the house.
5. After about one week of use, submit another sample for analysis.

Properly Constructed Well Features:

1. A tight cover with a screened vent that will exclude surface water, dust, insects, etc.
2. The well casing should rise at least 6 inches above ground surface.
3. A water-tight casing should extend a minimum of 20 feet below ground level.
4. The well should be located at least 100 feet from any source of contamination such as a drain field, privy, barnyard, stream, or lake.